

# CERTIFICATE

No 190-023/08

# KOOPIA

## Product

ISOTEX panels.

## Manufacturer /Supplier

AS Viisnurk (Reg nr 11421437)  
Address: Rääma 31, 80044 Pärnu, EESTI.

## Product description and field of application

ISOTEX panels are based on softboard, thickness of 12mm. Panels are covered with paper.  
Density of panels: 250 kg/m<sup>3</sup> and thickness of 13mm.

Field of application: The classification is valid for the following end use conditions:  
ISOTEX panels are used for interior finishing in dry rooms.

## Classification standard

EN 13501-1:2007 "Fire classification of construction products and building elements. Part 1: Classification using test data from reaction to fire tests".

## Classification

Based on test results (EN 13823:2002 and EN ISO 11925-2:2002) for ISOTEX panels the reaction to fire classification is **D-s1, d0**.

## Basis

1. Assessment report No OÜ-29-08 (SB EstCert OÜ);
2. Test report No TM-19/05, 19.10.2005(TÜV);
3. Decision of the Board No 13/05/09.

## Appertaining documents

Quality inspections register R1.

## Quality control


Quality control is carried out according to the quality supervision contract No KJL-112/2008.

## Certificate validity conditions

Present certificate is valid from 22.10.2008, changed 18.05.2009, till 22.10.2013 provided that regular manufacturing instruction supervision is performed in due time and according note is made in register. Current certificate is not certificate of conformity according to the construction product directive 89/106/EEC, and doesn't give authority to affix CE marking to the product.



Accredited  
PC015

  
Janek Neltsas  
Member of Board

INSPECTA ESTONIA OÜ  
BETOONI 15/ PANEELI 5, 11415 TALLINN, ESTONIA, TEL (+372) 680 7748, FAX (+372) 680 7746, www.estcert.ee

 **inspecta**